Schema Engineering Ltd 2021.

- than 900mm.

- 38. Type Z bedding to be used in trafficked areas where the cover to the crown of the sewer is less
- greater than or equal to 900mm.
- 37. Type S bedding to be used in trafficked areas where the cover to the crown of the sewer is

35. Concrete Slab Protection to be provided in trafficked areas where the cover to the crown of the

- PROTECTION TO PRIVATE SEWERS: 36. Type S bedding to be used in non-trafficked areas.
- 33. Type S bedding to be used in non-trafficked areas. 34. Type S bedding to be used in trafficked areas where the cover to the crown of the sewer is
- 32. All connections to adoptable sewers to be made in vitrified clay only. PROTECTION TO ADOPTABLE SEWERS:-

greater than or equal to 1200mm.

sewer is less than 1200mm.

otherwise.

control officer. The contractor shall liaise with the building inspector with regard to making inspections at the appropriate stages of the work. 30. All private foul and storm water sewers shall be 100/110mm dia clayware or PVC unless stated

31. All shallow inspection chambers to be a depth of 600mm from cover to invert unless stated

gradient no flatter than 1 in 80 unless stated otherwise on the drawings.

otherwise. Storm sewers shall be laid at a gradient no flatter than 1 in 100, and foul sewers to a

- agreed otherwise. 28. Gully connections to be 150mm dia at a gradient no flatter than 1 in 150 unless stated otherwise. 29. The private foul and storm water drainage shall be subject to inspections by the local building
- 26. Sulphate resisting cement and concrete products to be used for foul sewerage. 27. All pipes entering or leaving manholes shall be laid with their soffits level, unless shown or
- 25. Manhole covers to be set flush with binder course on new road construction and raised to final levels when surface course is laid at later date.
- with the AW logo and the lettering 'SW' for surface water and 'FW' for foul water. 24. Where possible orientation of manhole access covers to be orthogonal with adjacent kerb line.
- requirements of Anglian Water with regards to submitting method statements, risk assessments etc for obtaining a 'permit to work' on the existing sewer. 23. Where drainage is to be adopted, manhole covers are to be permanently and visibly badged
- standards and in accordance with Anglian Water's Additions and Deletions document. 22. Connections to the existing sewers shall be subject to the approval of Anglian Water and shall be carried out by a contractor approved by Anglian Water. The contractor shall comply with the
- sewers. Any work carried out without doing this is entirely at the contractor's own risk. 21. All adoptable drainage to be installed/constructed to 'Sewers for Adoption 6th Edition'
- 20. Prior to commencing any drainage works the contractor shall check and confirm back to Schema Engineering Ltd the existing invert level of all outfalls and/or connections to existing
- in accordance with BRE365 and results forwarded to the engineers to allow verification of designs.
- and such shoring is to be adequately founded and braced.
- onsite porosity tests at the location and depth of each soakaway. Tests should be undertaken
- any existing structures on the site and adjoining sites, taking all necessary precautions to 9. As underlying ground conditions may be variable across the site the contractor shall undertake

- 18. The main contractor is responsible for achieving and maintaining the stability of earthworks and safeguard this stability. Adequate shoring is to be inserted during the works to ensure stability
- others.

- 17. For details of landscaping and planting please refer to the landscaping drawing prepared by
- 16. For precise positions and details of domestic paths, sheds, bin stores, washing lines etc please refer to the architects drawings.
- 15. No trees, hedges or shrubs shall be taken up or otherwise damaged unless noted to the contrary on the drawings, or express permission is first obtained from the employer.
- and recommendations.
- 13. The contractor shall submit to the street works coordinator and utility companies the appropriate 'n' notices. Upon completion of the works the contractor shall submit to the street works coordinator the appropriate 'r' notice. 14. All proprietary materials shall be installed in accordance with the manufacturer's instructions
- County Council with regard to agreeing appropriate methods of traffic management. 12. The reinstatement of the highway shall be carried out fully in accordance with the HAUC 'Specification for the Reinstatement of Openings in Highways'. Reinstatement shall be permanent (on first visit). Trench backfill material shall be Type 1 granular sub-base.
- provide, erect, maintain and remove upon completion all temporary signing required for works carried out within the highway. The contractor shall liaise with the highways inspector of Norfolk
- 10. The surface course on the access road shall be deferred until building work for the whole flush with the base course and raised at the time the surface course is constructed. . All works within the existing highway shall be carried out fully in accordance with the New Works and Street Works Act 1991 and to Chapter 8 of the Traffic Signs Manual. The contractor shall
- contractor. development is complete. Gully frames and grates and other ironwork shall be temporarily set
- All existing services, sewers and drains indicated on this and any other related drawings are shown only indicatively, and shall have their position and level confirmed on site by the
- Existing public utility services and private apparatus are not necessarily all shown on this drawing. The contractor shall liaise with the appropriate utility provider to determine precisely where on site existing services are located. Services shall be located and marked out on site prior to any excavation work being commenced.
- 7. The contractor is to verify the accuracy of information provided by others.
- This drawing is based on a topographical survey and planning drawings by xxx xxx Ltd Architects. Dimensions are stated in meters unless shown otherwise. Chainages are stated in metres. Levels are in metres and related to ordnance datum.
- used.

CDM REGULATIONS HEALTH AND SAFETY INFORMATION FOR

The hazards noted are in addition to the normal hazards and  $\widehat{}$ 

risks faced by a competent contractor when dealing with the

HE LIFETIME OF THE DEVELOPMENT

type of works detailed on this drawing.

MAINTENANCE/CLEANING RISKS:

DEMOLITION / ADAPTION RISKS:

PRELIMINARY DRAWING:

as a construction issue.

written consent from Schema Engineering Ltd.

specialist's drawings.

Notes

1. To be confirmed at detailed design stage.

1. To be confirmed at detailed design stage.

1. To be confirmed at detailed design stage.

CONSTRUCTION RISKS:

4. This document has been prepared in accordance with the scope of Schema Engineering Ltd appointment with its client and is subject to the terms of that appointment. Schema Engineering Ltd accepts no liability for any use of this document other than by its client and only for the purposes for which it was prepared and provided. Only written dimensions shall be

propping & bracing is to be adequately founded to ensure the stability/integrity of the

1. This drawing is to be read in conjunction with all relevant structural engineer's drawings and details, the specification for the works, the relevant architect's drawings and any other

2. Any discrepancies found on this or any other drawings are to be reported to and resolved by

Schema Engineering Ltd before the commencement of any work relevant to the discrepancy.

The principal contractor is to provide fully designed propping/shoring to facilitate the works. All

existing/proposed structures &/or earthworks is maintained. Unless indicated on the drawings, the temporary works are not to impose reactions on the permanent structure without prior

arm

This drawing is for preliminary purposes only and must not be read

The design is not fixed and design changes are likely.

